

2430 "E" Street, N. W.
Washington, D. C.
3 December 1953

25X1A9a



25X1A9a

Weatherstripping for exterior doors
Dear Mr. [REDACTED]:

The enclosed prints of "Details for Weatherstripping on bottom of Exterior Doors" are submitted herewith as a supplemental drawing covering detail noted in specification, Paragraph 18.32. 18.31

As stated in answer to your teletype, dated 27 November 1953, subject "Weatherstripping", the weatherstripping on bottom of doors is desired on all exterior doors that have metal thresholds. Since it has been agreed, as a minor modification to the specification to omit the weatherstrip on hollow metal doors that have no metal thresholds, it is requested that the Contractor furnish weatherstrips for exterior wood doors with metal thresholds.

If the Contractor feels that this request would entail additional cost, please have him submit a proposal and make allowance for the metal doors on which the weatherstrip can be omitted.

Very truly yours,



25X1A9a

Attachments

5 prints of Drawing No. C-6